BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2468

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

NB380-H2L 2-Wire Conventional Heat Detector with Remote LED Output
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Wizmart Technology Inc.
Building B, No 88, Changyang Road
Jiangbei Investment Pioneering Park
Ningbo, Zhejiang
315033
China

and produced in the manufacturing plant(s):

Wizmart Technology Inc.
Building B, No 88, Changyang Road
Jiangbei Investment Pioneering Park
Ningbo, Zhejiang
315033
China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2017 + A1:2018 - Heat detectors - Point detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 06 April 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

P. Halligan.

P Halligan, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 6 April 2020

Date of Issue: 16 May 2022

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2022

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2468

NB380-H2L 2-Wire Conventional Heat Detector with Remote LED Output

Notes:
1. Meets the requirement of Class A1R

Base:
972914 Low profile 100mm diameter base with remote LED Connection

Variant:
NB380F-H2L 2-Wire Conventional Heat Detector with Remote LED Output (LED Flashes when Quiescent)

P. Halligan.

P Halligan, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 6 April 2020
Date of issue: 16 May 2022
Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2022