LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 1163g Issue: 02

Wizmart Technology Inc.

Building B, No 88, Changyang Road
Jiangbei Investment Pioneering Park
Ningbo 315033
Zhejiang
China

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Heat Detectors

NB380-H2
NB380-H2L
NB380-H4R
NB380F-H2
NB380F-H2L
NB380F-H4R
(refer to Appendix for details)

Standards

EN 54-5:2017 + A1:2018

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue
P. Halligan	P Halligan	16 May 2022	6 April 2020

This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

© BRE Global Ltd, 2022

80018

LPCB®

Appendix to Certificate No: 1163g

Issue: 02

Wizmart Technology Inc.

Certified Product	Description	LPCB Ref.No.
NB380-H2	2-Wire Conventional Heat Detector (972913 Base) Note: 1. Meets the requirement of Class A1R	1163g/01
NB380-H2L	2-Wire Conventional Heat Detector with Remote LED Output (972914 Base) Note: 1. Meets the requirement of Class A1R	1163g/02
NB380-H4R	4-Wire Conventional Heat Detector with Relay Output (972915 Base) Note: 1. Meets the requirement of Class A1R	1163g/03
NB380F-H2	2-Wire Conventional Heat Detector (LED Flashes when Quiescent) (972913 Base) Note: 1. Meets the requirement of Class A1R	1163g/04
NB380F-H2L	2-Wire Conventional Heat Detector with Remote LED Output (LED Flashes when Quiescent) (972914 Base) Note: 1. Meets the requirement of Class A1R	1163g/05
NB380F-H4R	4-Wire Conventional Heat Detector with Relay Output (LED Flashes when Quiescent) (972915 Base) Note: 1. Meets the requirement of Class A1R	1163g/06

Bases

972913	Low profile 100mm diameter base
972914	Low profile 100mm diameter base with remote LED Connection
972915	Low profile 100mm diameter base 4 wire

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd	Verifier	Date of Issue	Date of First Issue
P. Halligan	P Halligan	16 May 2022	6 April 2020

This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

© BRE Global Ltd, 2022

80018